



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received

Code 62.2-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

| | | |
|--|---------------------|-------------------------|
| Code Title Indiana Residential Code | | Edition 2009 |
| Section number and title TABLE E3801.4 | | Page 676 |
| Proponent Charlie Eldridge | Title Consultant | |
| Address 551 Grassy Ln., Indianapolis, IN 46217 | | Phone (317) 370-3444 |
| PROPOSED CODE CHANGE (Check One) | | |
| <input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution | | |
| The line, labeled "Run exposed and subject to physical damage", of the column, labeled "EMT", delete "--" and insert "A". | | |
| REASON AND FISCAL IMPACT | | |
| This text was extracted from the 2005 Indiana Residential Code. The NEC prohibits EMT where it is subject to <u>severe</u> physical damage. | | |
| REVIEW RECOMMENDATION | | |
| Approve | | |
| Disapprove | | |
| Approve as amended | | |
| Further Study | | |